



Government Of West Bengal
Office Of The Divisional Fire Officer, Darjeeling
West Bengal Fire & Emergency Services
Station Feeder Road, P.O & P.S Siliguri,
District: Darjeeling, Pin - 734005

Memo no.: IND/WB/FES/20192020/75531

Date: 05-06-2023

From:

Divisional Fire Officer, Darjeeling
West Bengal Fire & Emergency Services

To: Vidyasagar College of Education

Rupandighi, Phansidewa, Matigara, Darjeeling

Sub: Issuance of renewal of Fire Safety Certificate for the G+2 storied educational building under group Educational in name Vidyasagar B-Ed Collage at Rupandighi, P.O. Phansidewa Dist: Darjeeling (W.B), with some condition which will be complied by the applicant within the next 6 (six) months and the completion certificate should be submit to this office.

This is in reference to your application no. 0125191230500307 dated 17-05-2023 regarding the Issuance of renewal of Fire Safety Certificate for the G+2 storied educational building under group Educational in name Vidyasagar B-Ed Collage at Rupandighi, P.O. Phansidewa Dist: Darjeeling (W.B), with some condition which will be complied by the applicant within the next 6 (six) months and the completion certificate should be submit to this office.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

Subject to fulfillment following conditions

- 1) Another external staircase with width 2.mt. should be provide from the terrace to ground floor.
- 2) The under ground water reservoir capacity for fire fighting should be 25000 It. and one no. of electrical motor driven pump with capacity 900 lpm along with another stand by pump with same capacity should be provided.
- 3) Good housekeeping to be maintained both inside as well as outside the building
- 4) Floor Numbers as well as directional signs of escape routes to be prominently displayed
- 5) Fire Notice for evacuation and fire fighting to be prepared to display at all vulnerable places in the building

- 6)The occupants, employees and security staff to be made well-conversant about the installed fire safety and protection measures for their use in exigencies
- 7)Mock practice and fire evacuation drills to be organized for the regular periodical performance in accordance to the National Building Code - Part IV.
- 8)Electrical wiring of the afore said building should be checked and maintence to be done by an licensed electrician.
- 9)Trained Firemen and Fire Officers in the form of prescribed crew to be maintained for round the clock safety of the establishment.
- 10)Mock practice and fire evacuation drills to be organized for the regular periodical performance in accordance to the National Building Code - Part IV.
- 11)All Exit & Entrance should be free from obstruction.

This certificate is valid for 3 year u/r 18 of WBFS (Fire Prevention and Safety) Rules,2003 and renewable to after 3 year from the date of issue failing which this shall be revoked automatically.

Signature valid

Digitally Signed
Name: SHUVRA KISHOR MAZUMDER
Date: 05-Jun-2022 11:46
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Darjeeling
West Bengal Fire & Emergency Services